



NAIVASHA WATER & SANITATION COMPANY LTD.

NAIVASHA AOD PROJECT CLARIFICATION 1:

19th March, 2026

**GOAL: RESPONSE TO REQUEST FOR INFORMATION/CLARIFICATION BY A
BIDDER**

1. Item A3008 – The unit is indicated as Number (No.), whereas the item refers to pipes, which are typically measured in linear metres (LM). We kindly request confirmation on the correct unit of measurement for this item.

Response: The entire bill 3 (Customer Water Meters) has been revised to clarify on the required scope, materials type, pressure rating required, item descriptions and correct units of measurement. Please find attached with this clarification an excel revised bill 3 for use in this tender (replacing the initially provided bill 3 entirely).

2. Items B5002, B5002, and B7012 – These items are listed in the BOQ; however, the quantities indicated are zero (0). We request clarification on whether these items are to be considered during pricing or if they were included in the BOQ inadvertently.

Response: Bidders to provide rates for all items provided in the BOQs including those whose quantities are provided as zero (0) or dashes (-).

3. NCA Requirements – With reference to Pages 1–3 of the tender document and Section III – Evaluation and Qualification Criteria (MR 9), we request clarification on the National Construction Authority (NCA) registration requirement. Specifically, kindly confirm whether the required NCA category and registration certificate should be provided at the time of bid submission or will be required only from the successful bidder during contract award.

Response: It is mandatory that bidders submit a valid copy of certificate of registration with National Construction Authority (NCA) 3 and above (Water Category) in their tender at submission time.

4. On NCA refer to pg 1-3 and section III - evaluation and qualification criteria (MR 9) read them together and guide.

Response: There is a contradiction between NCA requirements provided on clause 3.12 under Eligible Tenders (Page 1-3) and that provided under Mandatory requirements (MR 9). It is hereby clarified that the Mandatory requirement (MR 9) provision will be strictly followed and that clause 3.12 under the eligible tender section is hereby declared not applicable for this tender.

5. Kindly give a clarification on Bill No. 5, Items B5001 & B5002, if there are missing values in the quantities column. PS; The quantities for Hydrostatic testing, sterilization and excavation tally at 3,715 metres but quantities for the pipework are indicated as zero

Response: Yes, there are missing quantity values. Corrected quantity values for Item B5001 is 3,715 and that for Item B5002 is 0 as shown in the corrected BQ 5 extract below. Kindly use the corrected quantity values in your bids.


NAIVASHA WATER & SANITATION
COMPANY LTD

ITEM No.	DESCRIPTION	Unit	Quantity	Rate	Amount
B5001	DN 160mm PN16	m	3715		
	<u>Double flanged epoxy steel pipe</u>				
B5002	Handle, transport and lay 200 mm double flanged steel pipe, PN 12.5	m	0		

6. The uploaded BoQ for Tender No: NAIVAWASCO/AOD/01/2025-26 Tender Name: NAIVASHA AOD PROJECT has a page skip error from page 8. Kindly share an editable format of the same.

Response: The BQ already provided is in excel format and editable. Thus no other BQ will be provided except bill 3 of the BQ as guided in response 1 above.

Yours Faithfully,



Eng. Nahashon Wahome
Managing Director